



Popeyes Louisiana Kitchen

400 Perimeter Center Terrace, Suite 1000
Atlanta, GA 30346

Design & Construction Field Bulletin

Date	May 2, 2016 (Issuance #001)
Field Bulletin No.	FB-004 2016 (1 pages)
Category	Mechanical
Subject	Captive Aire Hood Ansul Discharge Piping & Nozzles
Prototype Set Referenced	PLK 15 Series Drawings
Prototype Drawings Referenced	Captive Aire Sheet 3/M3
D&C Contact	design@popeyes.com

Comments

All the fryer vats should fall within the protected area of the Ansul system above. Fire inspections are being failed because of inadequate coverage.

Refer to the following drawing to ensure that the correct installation of the nozzles.

Correct Installation

