



**Popeyes Louisiana Kitchen**  
 400 Perimeter Center Terrace, Suite 1000  
 Atlanta, GA 30346

## Design & Construction Field Bulletin

Date	June 6, 2016 (Issuance #002)
Field Bulletin No.	FB-005 2016 (1 pages)
Category	Kitchen Equipment
Subject	Exhaust Hood Canopy (Tag F-71)
Prototype Set Referenced	PLK 15 Series Drawings
Prototype Drawings Referenced	Sheets K1 & K2a
D&C Contact	design@popeyes.com


**Comments**

Some of the franchisees' architects and engineers are including the exhaust hood above the Biscuit Holding unit and the Double Deck convection oven as a part of their standard kitchen equipment list. This hood should be listed as "Optional", because not all jurisdictions require a hood above these pieces of equipment.

Refer to the kitchen equipment sheets for the change in the need of the hood to "Optional".

**Drawing**

**F71 Exhaust hood (Optional)**



**1 EQUIPMENT PLAN**  
K1 1/4"=1'-0"

	F	Ventilation		
	1	F15	Exhaust Hood, Back Shelf, 6-20" Fryers	Captive Aire 2812BLL
	1	F15.1	Heated Holding Unit, Wall mount	Kitchen Equip. Supplier Custom (PC-HPL52-26)
2	1	F23	Exhaust Hood, Back Shelf, 2-Y4" Fryers	Captive Aire 2812BLL
	1	F71	Exhaust Hood, Canopy - Optional	Captive Aire 5424ND-2
		G	Shelving	
	1	GT.254	Storage Shelving, 4Tier, 21" Wide, 54" Long	Intermetro 2-MQ2154G/2-MHP2154G-
	2	GT.348	Storage Shelving, 4Tier, 24" Wide, 48" Long	Intermetro 2-MQ2448G/2-MHP2448G-
	5	GT.354	Storage Shelving, 4Tier, 24" Wide, 54" Long	Intermetro 2-MQ2454G/2-MHP2454G-

**K2a EQUIPMENT SHEET**