

BULLETIN NO. 1

**PROJECT: WT DEVELOPMENT
TACO BELL RESTAURANT
SOUTHGATE, MICHIGAN**

14 AUG 2018

This bulletin is issued subsequent to award of contract to amend the Contract Documents identified as above.

This bulletin shall apply to all applicable provisions of General and Supplementary Conditions and other contract documents as though items included were part of said contract documents as originally issued.

Except as otherwise specifically mentioned, the general character of the work required by the addendum shall be the same as originally specified, and all incidentals required in connection with the work hereinafter described shall be included even though not specifically mentioned. Where an item is mentioned with no additional specifications given, reference is to be made to the original specifications.

No documents issued with this Bulletin.

Item No. 1

Storm manhole MH-2 relocated approximately 4 feet north. Electric, telephone, and cable route have been relocated according to the revised plans. DTE will require one 4" Schedule 40 conduit instead of two conduits.

Item No. 2

Taco Bell requires that the ADA parking area and access aisle be constructed of concrete pavement. This area is identified in the revised plans. Construction of the pavement shall be in accordance with detail 5/C3.1 of the plans.

END OF BULLETIN NO. 1