

CEMETITIUOS COATING ON 18 GA GALV MET LATH ON ONE LAYER 30# FELT ON 5/8" EXT PLYWOOD ALUMINUM CAP FLASHING CONT K.O. BLK W/CONC & 1-#5 SECURE A/C UNIT TO CURB W/ 3/8"ø LAG BOLTS (TYP) 3 ON SHORT SIDE 5 ON LONG 6" MET CURB SECURE TO WD SHEATHING JOIST W/ 1" WIDE GALV MET STRAPS 1/2" DIA GALV ANC BOLTS @16"O.C. —— FILL CELLS IN CONC —1" GALV MET STRAPS TAPERED RIGID INSUL A/C SUPPORT DETAIL A

ROOF WOOD TRUSS NOTES:

HIP ROOF TRUSSES ARE TO BE DESIGNED BY THE TRUSS MANUFACTURER TO MEET OR EXCEED THE FOLLOWING LOAD CONDITIONS IN ADDITION TO ALL GOVERNING BUILDING CODES; COMPLETE WITH ALL NECESSARY TEMPORARY OR PERMANENT BRACING, ATTACHMENTS, BRIDGING, ETC. AS MAY BE REWUIRED FOR A COMPLETE ROOF SYSTEM.

TOP CHORD LIVE 22.0 psf.
TOP CHORD DEAD LOAD 12.0 psf.
BOTTOM CHORD LIVE LOAD 00.0 psf.
BOTTOM CHORD DEAD LOAD 10.0 psf.
TOTAL 44.0 psf.

DESIGN IS TO BE BASED ON FRAMING LAYOUT, DIMENSIONS AND LOADS SHOWN. DEVIATION FROM THIS MUST BE COORDINATED WITH PROJECT PROFESSIONAL.

OM THIS MOST BE COORDINATED WITH PROJECT PROFESSIONAL.

DESIGN COMPUTATIONS AND FRAMING LAYOUTS ARE TO BE SUBMITTED FOR APPROVAL TO DESIGN PROFESSIONAL OF RECORD AND MUST BEAR SEAL OF CURRENTLY REGISTERED PROFESSIONAL ENGINEER IN THE STATE OF FLORIDA. THE GENERAL CONTARCTOR IS REPONSIBLE FOR COORDINATION BETWEEN TRUSS FABRICATOR, ALL TRADES AND ENGINEER OF RECORD OR PROJECT DESIGNER.

WOOD	TABLE	NOTES:	
		_	

UIDENTIFICATION.

CLOAD-BEARING DIMENSION LUMBER FOR STUBS: PLANTES AND HEADERS SHALL BE IDENTIFIED BY A RADE MARK EOF A LUMBER GRADING OR

O A N A

INSPECTION AGENCY THAT HAS BEEN APPROVED BY AN ACCREDITATION BODY THAT COMPLIES WITH DOC PS
20. IN LIEU OF A GRADE

MARK, A CERTIFICATION OF INSPECTION ISSUED BY A LUMBER GRADING OR INSPECTION AGENCY MEETING THE REQUIREMENTS OF THIS

E S

SECTION SHALL BE ACCEPTED.

END-JOINTED LUMBER.

APPROVED END-JOINTED LUMBER IDENTIFIED BY A GRADE MARK. MAY BE USED INTERCHANGEABLY WITH SOLID-SAWN MEMBERS OF THE SAME SPECIES AND GRADE.

STRUCTURAL GLUED LAMINATED TIMBERS

STRUCTURAL GLUED LAMINATED TIMBERS.
GLUED LAMINATED TIMBERS SHALL BE MANUFACTURED AND IDENTIFIED AS REQUIRED IN AITCA190.1 AND ASTM D 3737.
GRADE.

STADES SHALL BE A MINIMUM NO. 3, STANDARD OR STUD GRADE LUMBER.
EXCEPTION: BEARING STUDS NOT SUPPORTING FLOORS AND NONBEARING STUDS MAY BE UTILITY GRADE
LUMBER, PROVIDED THE STUDS
ARE SPACED IN ACCORDANCE WITH TABLE

ROOF FRAMING PLAN

SCALE: 1/4"= 1'-0"

PLANS COMPLY WITH 2007 FLORIDA BUILDING CODES, EXISTING BUILDING CODE, FLORIDA MECHANICAL CODE, FLORIDA PLUMBING CODE, 2007 FLORIDA PREVENTION CODE, 2008 NATIONAL ELECTRIC CODE (N.E.C.), LEE COUNTY LAND DEVELOPMENT CODE (L.D.C.), AND FLORIDA STATUTES (F.S.) AS WELL AS OTHER CODES AND ORDINANCES AS ADOPTED BY LEE COUNTY, FLORIDA.