A. GENERAL

1. THE STRUCTURE IS DESIGNED TO BE SELF-SUPPORTING AND STABLE AFTER CONSTRUCTION IS FULLY COMPLETED. THE CONTRACTOR IS SOLELY RESPONSIBLE TO DETERMINE ERECTION PROCEDURE AND SEQUENCE TO ENSURE THE SAFETY OF THE BUILDING AND ITS COMPONENT PARTS DURING CONSTRUCTION, INCLUDING PROVISIONS FOR CHANGEABLE WEATHER UNTIL THE BUILDING IS ENCLOSED AND CONDITIONED. THE CONTRACTOR SHALL DESIGN, INSTALL AND SUBSEQUENTLY REMOVE ANY SHORING, SHEETING, TEMPORARY BRACING, GUYS OR TIEDOWNS NECESSARY TO MAINTAIN SAFETY AND STRUCTURAL STABILITY DURING CONSTRUCTION. ANCHOR RODS AT STEEL COLUMNS HAVE NOT BEEN DESIGNED FOR. AND WILL NOT PROVIDE. TEMPORARY BRACING OR SUPPORT FOR OTHER COLUMNS OR OTHER CONNECTED FRAMING MEMBERS DURING CONSTRUCTION.

- 2. THE CONTRACTOR IS SOLELY RESPONSIBLE TO FOLLOW ALL APPLICABLE SAFETY CODES, BUILDING CODES AND GOVERNING REGULATIONS WITH JURISDICTION OVER THE CONSTRUCTION SITE DURING ALL PHASES OF CONSTRUCTION.
- 3. ANY FRAMING SHOWN ON DRAWINGS THAT SUPPORTS EQUIPMENT (WHETHER SUPPORTED ABOVE OR SUSPENDED BELOW), DESIGN LOADS, OPENINGS AND PENETRATIONS, AND STRUCTURAL MEMBERS IN ANY MANNER RELATED TO HVAC, PLUMBING, ELECTRICAL OR FIRE PROTECTION REQUIREMENTS IS BASED ON EQUIPMENT DESIGNED, SHOWN AND/OR SPECIFIED IN THE CONSTRUCTION DOCUMENTS. ALL REQUIRED FRAMING MAY NOT BE SHOWN. USING THE DETAILS PROVIDED ON THE STRUCTURAL DRAWINGS, THE GENERAL CONTRACTOR AND SUB-CONTRACTORS AND/OR EACH PRIME CONTRACTOR MUST COORDINATE AND INSTALL THE ACTUAL FRAMING REQUIRED FOR THE EQUIPMENT TO BE INSTALLED, AND INCLUDE COSTS FOR ALL REQUIRED FRAMING IN THE BID. IF THE CONTRACTOR REQUESTS AND RECEIVES APPROVAL TO SUBSTITUTE EQUIPMENT, THE CONTRACTOR MUST ALSO INSTALL THE FRAMING REQUIRED FOR THE SUBSTITUTED EQUIPMENT AS WELL, WITHOUT ADDITIONAL COST TO THE PROJECT, INCLUDING ANY AND ALL FEES REQUIRED BY THE ARCHITECT AND/OR ENGINEERS TO RE-DESIGN AND REVISE THE CONSTRUCTION DOCUMENTS.
- 4. SHOULD ANY OF THE DETAILED INSTRUCTIONS SHOWN ON THE PLANS CONFLICT WITH THESE STRUCTURAL NOTES, OR WITH EACH OTHER, THE STRICTEST PROVISION SHALL
- 5. DESIGN BASIS: 2020 FLORIDA BUILDING CODE, INCLUDING ALL ADOPTED REFERENCE STANDARDS AND MATERIAL SPECIFICATIONS REFERENCED THEREIN.

6. DESIGN CRITERIA

a. ROOF LOADING 1. DESIGN ROOF LIVE LOAD (MINIMUM) 20 PSF 2. THE ROOF STRUCTURE HAS BEEN DESIGNED FOR THE ROOF LOADINGS INDICATED ABOVE SUCH THAT AN ADEQUATE ROOF SLOPE AND DRAINAGE SYSTEM ARE REQUIRED TO PREVENT PONDING LOADS WHICH MAY EXCEED THE DESIGN ROOF LOADS.

150 MPH.

+0.18, -0.18

+74.7 PSF, -81.6 PSF

+31.7 PSF, -36.1 PSF

1.0

- b. WIND LOADING 1. BASIC WIND SPEED 2. WIND IMPORTANCE FACTOR 3. OCCUPANCY CATEGORY
- 4. WIND EXPOSURE CATEGORY 5. INTERNAL PRESSURE COEFFICIENT 6. COMPONENTS AND CLADDING:
- b. WALLS c. SEISMIC DESIGN CRITERIA 1. SEISMIC IMPORTANCE FACTOR
- 2. OCCUPANCY CATEGORY 3. MAPPED SPECTRAL RESPONSE ACCELERATIONS: a. SHORT PERIODS 0.086q
- b. 1 SECOND PERIOD 4. SITE CLASS D (ASSUMED) 5. SPECTRAL RESPONSE COEFFICIENTS: a. DESIGN SPECTRAL RESPONSE
- ACCELERATION AT SHORT PERIODS = 0.052g b. DESIGN SPECTRAL RESPONSE ACCELERATION AT 1 SECOND PERIOD = 0.048g 6. SEISMIC DESIGN CATEGORY
- 7. ANALYSIS PROCEDURE: EQUIVALENT LATERAL FORCE PROCEDURE e. ALL NEW FRAMING MEMBERS HAVE BEEN DESIGNED TO MEET THE CODE MINIMUM LIVE LOAD AND TOTAL LOAD DEFLECTION CRITERIA.
- 7. COORDINATE ALL DIMENSIONS AND ELEVATIONS WITH THE ARCHITECTURAL DRAWINGS. SEE THE ARCHITECTURAL DRAWINGS FOR DIMENSIONS AND ELEVATIONS NOT SHOWN. ALL DIMENSIONS AND ELEVATIONS SHOWN ON THE STRUCTURAL DRAWINGS ARE INTENDED TO AUGMENT, NOT SUPERSEDE, THOSE SHOWN ON THE ARCHITECTURAL DRAWINGS. DO NOT SCALE THE DRAWINGS. DRAWINGS MAY NOT BE TO SCALE.
- 8. EXISTING BUILDING: INSTALL TEMPORARY SUPPORTS AND OTHER MEASURES AS REQUIRED TO PREVENT DAMAGE TO THE EXISTING BUILDING DURING CONSTRUCTION. THE CONTRACTOR IS RESPONSIBLE FOR THE DESIGN, INSTALLATION AND FINAL CLEARANCE OF REQUIRED NEEDLING, SHORING, UNDERPINNING OR BRACING OF THE EXISTING BUILDING. FIELD VERIFY ALL EXISTING DIMENSIONS, ELEVATIONS AND CONDITIONS WHICH AFFECT THE NEW CONSTRUCTION PRIOR TO THE START OF WORK. EXISTING CONDITIONS SHOWN ON THE DRAWINGS ARE BASED ON THE ORIGINAL CONSTRUCTION DRAWINGS PROVIDED BY THE ARCHITECT AND HAVE NOT BEEN CONFIRMED, ARE NOT GUARANTEED AND MAY CONFLICT WITH THE NEW WORK REQUIRED. FIELD VERIFY THAT THE EXISTING FRAMING AFFECTED BY THE NEW WORK IS IN SOUND CONDITION AND DOES NOT DISPLAY VISIBLE SIGNS OF DISTRESS OR DETERIORATION OR HAS BEEN PREVIOUSLY MODIFIED OR ALTERED. IMMEDIATELY NOTIFY THE ARCHITECT OF ANY DISCREPANCIES BETWEEN THE INFORMATION SHOWN ON THE DRAWINGS AND ACTUAL FIELD CONDITIONS; DO NOT PROCEED WITH THAT PORTION OF WORK UNTIL ALL DISCREPANCIES HAVE BEEN RESOLVED. THE CONTRACTOR SHALL SUBMIT A FIELD SURVEY SHOWING ALL DISCREPANCIES BETWEEN THE EXISTING CONDITIONS AND THE NEW WORK. BASED ON THE REPORTED FIELD CONDITIONS. THE ARCHITECT WILL SUBMIT SUPPLEMENTAL INSTRUCTIONS FOR ALL WORK (NEW OR EXISTING) REQUIRING MODIFICATION.
- 9. ARCHITECTURAL ITEMS OR PREFABRICATED ITEMS SHOWN ON THE STRUCTURAL DRAWINGS ARE REFERENCED FOR GENERAL COORDINATION PURPOSES ONLY a. TYPICAL REFERENCED ARCHITECTURAL ITEMS INCLUDE BUT MAY NOT BE LIMITED TO: DRAINS, DRAIN TILES, FINISHES, DOORS, WINDOWS, AND ITEMS FOR THERMAL AND MOISTURE PROTECTION. SEE ARCHITECTURAL DRAWINGS AND SPECIFICATIONS FOR MATERIAL REQUIREMENTS, PLACEMENT AND EXACT LOCATION
- b. TYPICAL REFERENCED PREFABRICATED ITEMS INCLUDE BUT MAY NOT BE LIMITED TO: STAIRS, HANDRAILS, CURTAIN WALL/STOREFRONT SYSTEMS, AWNINGS, PREFABRICATED FRAMING AND COLD-FORMED STEEL FRAMING. SUCH SYSTEMS SHALL BE DESIGNED, FURNISHED AND INSTALLED AS REQUIRED BY OTHER PORTIONS OF THE CONTRACT DOCUMENTS.

B. REINFORCED CONCRETE

- 1. ALL CONCRETE CONSTRUCTION SHALL CONFORM TO THE LATEST, ADOPTED EDITIONS OF THE STANDARDS AND MATERIAL SPECIFICATIONS REFERENCED HEREIN.
- REFERENCE STANDARDS BY THE AMERICAN CONCRETE INSTITUTE (ACI) a. ACI 301, "SPECIFICATIONS FOR STRUCTURAL CONCRETE," EXCEPT AS SPECIFICALLY MODIFIED IN THE SPECIFICATIONS AND/OR HEREIN.
- b. ACI 318, "BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE."
- c. ACI 305, "HOT WEATHER CONCRETING" AND ACI 306, "COLD WEATHER CONCRETING." d. ACI 315, "DETAILS AND DETAILING OF CONCRETE REINFORCEMENT" UNLESS DETAILED OTHERWISE ON THE STRUCTURAL DRAWINGS.

3. MATERIALS a. STRUCTURAL CONCRETE

CLASS	LOCATION	f'c (psi)
I	NOT USED	3,000
II	INTERIOR SLABS ON GRADE AND ALL INTERIOR CONCRETE NOT OTHERWISE IDENTIFIED	3,500
III	EXTERIOR SLABS ON GRADE, AND ALL EXTERIOR CONCRETE NOT OTHERWISE IDENTIFIED	4, <i>000</i> (with air)

- b. ALL WELDED WIRE FABRIC: ASTM A185, DELIVERED IN FLAT SHEETS.
- 4. FIELD MANUAL: PROVIDE AT LEAST ONE COPY OF THE ACI FIELD REFERENCE MANUAL, SP-15, IN THE FIELD OFFICE AT ALL TIMES.
- 5. CONCRETE COVER: UNLESS NOTED OTHERWISE, DETAIL REINFORCING TO PROVIDE MINIMUM CONCRETE COVER AS FOLLOWS: a. CONCRETE CAST AGAINST AND PERMANENTLY
- EXPOSED TO EARTH 3 INCHES b. CONCRETE EXPOSED TO EARTH OR WEATHER 1-1/2 INCHES #5 BARS AND SMALLER 2 INCHES

C. STRUCTURAL LUMBER

- 1. ALL STRUCTURAL LUMBER CONSTRUCTION SHALL CONFORM TO THE LATEST, ADOPTED EDITIONS OF THE STANDARDS AND MATERIAL SPECIFICATIONS REFERENCED HEREIN.
- 2. REFERENCE STANDARD a. NDS, "NATIONAL DESIGN SPECIFICATION FOR WOOD CONSTRUCTION" BY THE AMERICAN FOREST & PAPER ASSOCIATION (AF & PA).

3. MATERIALS

- a. ALL LUMBER SHALL COMPLY WITH THE REQUIREMENTS OF DOC PS 20. FURNISH LUMBER WITH EACH PIECE FACTORY-MARKED WITH GRADE STAMP OF INSPECTION AGENCY VERIFYING COMPLIANCE WITH GRADING RULE REQUIREMENTS AND IDENTIFYING GRADING AGENCY, GRADE, SPECIES, MOISTURE CONTENT AND MILL. b. ALL WOOD STRUCTURAL PANELS SHALL COMPLY WITH REQUIREMENTS OF DOC PS 1 DOC PS 2, HPVA HP I AND APA PDS. FACTORY-MARK ALL WOOD STRUCTURAL PANELS
- WITH A GRADING STAMP OF THE INSPECTION AGENCY. c. STUDS: SPRUCE-PINE-FIR, STUD GRADE OR BETTER, ACCORDING TO THE NATIONAL
- LUMBER GRADES AUTHORITY (NLGA), SEASONED AT 19% M.C. d. STRUCTURAL LUMBER: SPRUCE-PINE-FIR NO. 2 OR BETTER, ACCORDING TO THE
- NATIONAL LUMBER GRADES ASSOCIATION (NLGA), SEASONED AT 19% M.C. e. WOOD STRUCTURAL PANELS (PLYWOOD OR ORIENTED STRAND BOARD):
- 1. ROOF: 19/32" (5/8" NOMINAL), APA RATED SHEATHING, 40/20, EXPOSURE 1, U.N.O.
- 2. WALL: 15/32" (1/2" NOMINAL), APA RATED SHEATHING, 32/16, EXPOSURE 1.

f. FASTENERS

- 1. NAILS: COMMON STEEL WIRE NAILS, CONFORMING TO ASTM F1667. 2. WOOD SCREWS: FLAT HEAD, CONFORMING TO ANSI/ASME STANDARD B18.6.1. 3. BOLTS, NUTS AND WASHERS: CONFORM TO ASTM A307, ASTM A563 AND ASTM F436, RESPECTIVELY.
- q. WOOD-PRESERVATIVE TREATMENT: COMPLY WITH THE APPLICABLE REQUIREMENTS OF AWPA STANDARD U1. MARK EACH TREATED ITEM WITH THE APPROPRIATE QUALITY
- 4. CONNECTIONS: AS A MINIMUM, CONFORM CONNECTIONS FOR STRUCTURAL MEMBERS TO THE FASTENING SCHEDULE LISTED IN INTERNATIONAL BUILDIN CODE.
- a. PROVIDE GALVANIZED CONNECTORS BY THE SIMPSON STRONG-TIE CO. INSTALL ALL CONNECTORS IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS
- b. WOOD STRUCTURAL PANELS TO WOOD ROOF RAFTERS: NAILED, USE 10d COMMON NAILS SPACED AT 6 INCHES O.C. AT PANEL EDGES AND 12 INCHES O.C. AT INTERMEDIATE SUPPORTS. INSTALL PLYWOOD CLIPS AT MID-SPAN OF PLYWOOD BETWEEN SUPPORTS.
- c. WOOD STRUCTURAL PANELS TO WOOD STUDS: USE 10d COMMON NAILS SPACED AT 6 INCHES O.C. AT PANEL EDGES AND 12 INCHES O.C. AT INTERMEDIATE SUPPORTS.
- BLOCK ALL EDGES WITH FULL-DEPTH BLOCKING. d. PROVIDE GALVANIZED FASTENERS FOR ALL EXTERIOR APPLICATIONS AND FOR ALL WOOD-PRESERVATIVE TREATED MATERIALS.
- e. AT POSTS AND JAMBS OF OPENINGS, NAIL MULTIPLE STUDS TOGETHER WITH 8d NAILS AT 8" O.C., FULL LENGTH. f. FASTEN WOOD PLATES TO THE TOP FLANGE OF STEEL BEAMS WITH 1/2" DIAMETER BOLTS SPACED AT 24" O.C. (STAGGERED ON OPPOSITE SIDES OF WEB). PLACE

5. MISCELLANEOUS a. INSTALL FULL-DEPTH SOLID BLOCKING AT RAFTER BEARING LOCATIONS. INSTALL

BOLTS IN 9/16" DIAMETER DRILLED HOLES (IN BOTH WOOD AND STEEL).

- ONE LINE OF SOLID BLOCKING OR CROSS BRIDGING AT 8'-O" O.C. MAX. FOR ALL RAFTERS. b. AT ALL EXTERIOR STUD WALLS INSTALL A CONTINUOUS LINE OF SOLID BLOCKING AT
- MID-HEIGHT OF THE WALL, BUT AT NO GREATER THAN 5'-O" ON CENTER MAXIMUM. c. UNLESS NOTED OTHERWISE, INSTALL MINIMUM DOUBLE JACK BEARING STUDS UNDER
- EACH END OF ALL BEAMS, BUT NOT LESS THAN THE NUMBER REQUIRED TO PROVIDE FULL-WIDTH SOLID BEARING OF THE SUPPORTED MEMBERS. d. INSTALL STANDARD THREE-STUD CORNER CONSTRUCTION AT INSIDE AND OUTSIDE
- CORNERS, PROVIDING NAILING SURFACES FOR SHEATHING. INSTALL BLOCKING AS
- e. AT DOOR AND WINDOW OPENINGS IN EXTERIOR WALLS, INSTALL A MINIMUM OF TWO JACK BEARING STUDS AND TWO FULL-HEIGHT KING STUDS AT EACH END OF HEADERS, UNLESS NOTED OR SCHEDULED OTHERWISE.
- f. UNLESS NOTED OTHERWISE, INSTALL DOUBLE 2 X 10 HEADERS OVER OPENINGS IN 2 X 4 STUD WALLS AND TRIPLE 2 X 8 HEADERS OVER OPENINGS IN 2 X 6 STUD WALLS.
- q. INSTALL ONE LAYER OF 1/2" THICK WOOD STRUCTURAL PANEL BETWEEN EACH MEMBER OF DIMENSIONAL LUMBER HEADERS. h. TREAT ALL EXTERIOR LUMBER OR LUMBER IN CONTACT WITH CONCRETE OR MASONRY
- WITH PRESERVATIVE IN ACCORDANCE WITH AMPA. 1. INSTALL WOOD STRUCTURAL PANEL WALL SHEATHING ON ALL EXTERIOR WALLS. HOT-DIP GALVANIZE ALL STEEL CONNECTORS AND PRODUCTS 14 GA. AND THICKER
- AFTER FABRICATION THAT ARE IN CONTACT WITH PRESERVATIVE-TREATED WOOD. PROVIDE MINIMUM 2.0 OZ. COATING, ALL SIDES, PER ASTM A123. PROVIDE HOT-DIPPED GALVANIZED CONNECTORS PER ASTM A153 OR STAINLESS STEEL
- HOT-DIP GALVANIZE ALL STEEL CONNECTORS AND PRODUCTS LESS THAN 14 GA. THICK AFTER FABRICATION THAT ARE IN CONTACT WITH PRESERVATIVE-TREATED WOOD. PROVIDE MINIMUM 1.85 OZ. COATING, ALL SIDES, PER ASTM A653. PROVIDE HOT-DIPPED GALVANIZED CONNECTORS PER ASTM A153 OR STAINLESS STEEL CONNECTORS.

D. STRUCTURAL STEEL

- a. SHAPES AND PLATES SHALL BE ASTM A36, U.N.O. b. BOLTS SHALL BE ASTM A325, 3/4" DIA. (MIN.), U.N.O.
- c. STEEL DESIGN IS BASED ON THE CURRENT AISC MANUAL OF STEEL CONSTRUCTION (ASD). d. WELDING ELECTRODES SHALL BE SERIES ETOXX.
- e. PERFORM WELDING IN ACCORDANCE WITH THE AMERICAN WELDING SOCIETY'S AWS DI.1 "STRUCTURAL WELDING CODE".
- f. STEEL FABRICATORS SHALL BE A COMPANY THAT IS CERTIFIED BY AISC.
- (NOTE IF NOT CERTIFIED BY AISC, THEN SPECIAL INSPECTION FOR REVIEW OF SHOP FABRICATION AND QUALITY CONTROL PROCEDURES IS REQUIRED.)
- q. SHOP PAINT: STANDARD RED PRIMER, U.N.O. IN SPECIFICATIONS. CONTRACTOR TO COORDINATE PAINT WITH PROPOSED FINISHES AS APPLICABLE.
- h. FASTENERS FOR PRESERVATIVE-TREATED AND FIRE-RETARDANT-TREATED WOOD SHALL BE HOT-DIPPED ZINC-COATED GALVANIZED STEEL.

ISSUE DATE: 12/xx/2021 PROJECT NUMBER: 21-121 DRAWN BY: CHECKED BY

SHEET NAME

RONALD A. ROBERTS, P.E.

2948 N. Stemmons Freeway Dallas, Texas 75247-6103 Phone: (214) 637-6299 www.rara.net

BUILDING TYPE: 3076 ASSET TYPE: FREESTANDING CLASSIFICATION: REFRESH OWNER: STARBOARD BASE VERSION: 2021 SPRING **UPGRADE CLASSIFICATION:** PROJECT YEAR: 2022 DESIGN TYPE: (2.0) UM BRIGHT DRAWING RELEASE: 2021 SPRING

00915

Linear Architecture LLC Philip Kemery, Architect

4436 Harvest Hill Rd. Dallas, TX 75244 PHONE: 972.929.9226

SITE NUMBER:



STARBOARD GROUP 12540 W. ATLANTIC BLVD. CORAL SPRINGS, FL 33071 OFFICE: (954)255-2266

119 MP

DESCRIPTION

FOUNDATION SECTIONS