

Addendum #2

Ampler Development
Project: Burger King Pennsburg, PA
Architect's Project No. 21-0327

Bidders,

You are hereby directed to make note of the following informational update and/or changes to the original Bid Documents and / or Specifications. Please incorporate the revised drawings into your bid sets.

Reference

1. Add 'Flagpole and light' under "Alternates and Extras" on the Budget Form.

Architectural

G-001:

1. Added sheet S-1.2 and revised Kitchen drawing numbers.

A-4:

2. Revised Dining room ceiling per Burger King prototype updates.

Structural

S-1:

1. Revised locations of drains.

S-1.2:

1. Added sheet

Kitchen

1. Replaced drawings with revised ones from vendor.

Plumbing

P-1

1. Updated location of floor sinks, grease waste, condensate and vent lines with relocated equipment and corresponding isometric diagrams.

P-2

2. Updated location of CW/HW/CF lines to relocated equipment and corresponding isometric diagram.

Electrical

E-1

1. Updated the lighting plan for the Dining area based on the revised Dining room ceiling changes.

E-1.1

2. Updated the Electrical equipment schedules based on the revised kitchen layout.

E-2

1. Updated the power plan based on the revised kitchen layout by adding two circuits for the fryer, relocated Electrical receptacle for BK/ fry freezer, and removed two receptacles for Ice machine (16.73) and smoothie blender (59C.02). Updated the Electrical equipment schedules based on the revised kitchen layout.

E-3

2. Added Circuit #16 for vat-fryer and circuit #46, 48, 50 for Combi oven Electric at panel-B. circuits #8 became spare at panel M.

End of Addendum #2