

**BULLETIN No. 1
to
CONSTRUCTION DOCUMENTS
for
Taco Bell
7931 Lapeer Rd
Davison, MI**

September 17, 2019

- A. The original construction documents for the above referenced project are hereby amended as noted in Bulletin No. 1.
- B. This Bulletin supersedes and takes precedence over information provided prior to the date of this Bulletin.

DRAWING REVISIONS:

Sheets A1.1, A4.1, A5.3

- 1. Drive-thru window has been revised to remove 6" storefront sill and revise sill height to elevation to be 3'-0" a.f.f.***

Sheet A6.4

- 1. Revised detail 3 to show flashing set in sealant.***

END OF BULLETIN No. 1