

ELECTRICAL SCHEDULES						
ITEM#	QTY	DESCRIPTION	110-120V/PH/60HZ	AMPS	AFF. (IN)	ELECTRICAL REMARKS
10.01	1	12 V SODA SYSTEM W/ICE	115V/1/60HZ	6	18	-
11.01	1	SODA SYSTEM, DROP IN BV W/ICE	115V/1/60HZ	1.5	18	-
11.02	3	CARBONATOR	115V/1/60HZ	3	84	-
14.17	1	FROZEN COKE MACHINE	VERIFY	VERIFY	VERIFY	VERIFY UTILITY REQUIREMENTS WITH OWNER PROVIDED EQUIPMENT
15.10	1	SHAKE & SOFT SERVE (3PH)	VERIFY	VERIFY	VERIFY	VERIFY UTILITY REQUIREMENTS WITH OWNER PROVIDED EQUIPMENT
16.63	1	CUBER, 1130 LB CAPACITY REMOTE AIR COOLED 1PH	208-230V/1/60HZ	13.5	60	20A MAX. FUSE SIZE
17.00	1	COFFEE/ TEA BREWER	120/208V/1/60	13	50	-
21.04A	1	FRONT PREP TABLE "A" (60") 8-PAN	120-208V/3/60HZ	LL:1104.7A L2:117.1A L3:115.7A	FR/CEILING	EC TO PLUG TABLES TOGETHER AND TO CONNECT BREAKER PANEL IN TABLE TO MAIN PANEL
21.85	1	BK MIDDLE PREP TABLE (BUN RACK)	-	-	-	EC TO PLUG TABLES TOGETHER
21.89	1	BK REAR PREP TABLE (REFRIG UNDERCOUNTER) 5 PANS	-	-	-	EC TO PLUG TABLES TOGETHER
21C.32	1	BK EXPEDITER STATION	120V/1/60HZ	6	-	CONNECT TO PRE-WIRED TO RECEPTACLE IN PREP TABLE (#21)
21C.45	1	BK BEVERAGE REFRIGERATOR-SLIME LINE	110-120V/1/60HZ	4	-	CONNECT TO PRE-WIRED TO RECEPTACLE IN PREP TABLE (#21) 15A MAX. FUSE SIZE
23.23	1	BROILER ISLAND HOOD W/ AMEREX	-	-	-	EC TO INTER-CONNECT FANS TO CONTROL PANEL AND ANSUL SYSTEM/ VERIFY WITH HOOD DRAWINGS
24.00	1	BROILER	120V/1/60HZ	2	-	PLUG TO RECEPTACLE UNDER HOOD/EC TO PROVIDE ELECTRICAL RECEPTACLE & COVER PLATE - REFER TO HOOD DRAWINGS
26.14	2	BK MEAT FREEZER 50"	4	3	18	-
30.17	1	UNIVERSAL FRY DUMP STATION S/S/NEXT GENERATION	120-208/1/60HZ	40	FR/CEILING	CIRCUIT 1 FRY DUMP: (120-208V/1/60HZ, 20A, 3 WIRE + GROUND), CIRCUIT 2 PHU: (208V/1/60HZ, 20A 2 WIRE + GROUND)
31.03	1	4 VAT FRYER	120V/1/60HZ	13	-	CORD & PLUG/ CONNECT TO RECEPTACLE PROVIDED UNDER HOOD/ REFER TO HOOD DRAWINGS
32.06	1	BK FRY FREEZER W/FRY BASKET HOLDER	120V/1/60	4	18"	-
32C.03	1	UNDERCOUNTER REFRIG	120V/1/60HZ	2.9	-	CONNECT TO PRE-WIRED TO RECEPTACLE IN PREP TABLE (#21)
33.22	1	9'-0" FRYER/OVEN HOOD FREE STANDING	110-120/1/60HZ	-	-	EC TO CONNECT RECEPTABLES AND INTER-CONNECT FANS TO CONTROL PANEL AND ANSUL SYSTEM/ VERIFY WITH HOOD DRAWINGS, EC TO PROVIDE ELECTRICAL RECEPTACLE FOR OVEN.
36.02	1	COMBI OVEN STEAMER ELECTRIC	208V/3/60HZ	20	-	EC TO CONNECT TO RECEPTACLE UNDER HOOD / VERIFY WITH OWNER & HOOD DRAWINGS
40.00	1	WALK-IN COOLER/FREEZER	-	-	-	EC TO PROVIDE ELECTRICAL CONNECTIONS FOR LIGHTS AND HEATERS AND TO INTERCONNECT EVAPORATOR COIL TO CONDENSING UNIT/ REFER TO WIB DRAWINGS
50.02	2	MICROWAVE OVEN	208-240V/1/60HZ	20	-	CONNECT TO PRE-WIRED TO RECEPTACLE IN PREP TABLE (#21)
51.13	2	PHU - 3X4	208V/1/60HZ	16	-	CONNECT TO PRE-WIRED TO RECEPTACLE IN PREP TABLE (#21)
51B.13	1	PHU - 2X4	208V/1/60HZ	12	-	CONNECT TO PRE-WIRED TO RECEPTACLE IN FRY DUMP (#30)
52.00	1	EGG COOKER	208V/1/60HZ	11.4	-	CONNECT TO PRE-WIRED TO RECEPTACLE IN PREP TABLE (#21)
53.13	1	REFRIG. UNDERCOUNTER	115V/1/60HZ	2.2	18	-
54.01	1	REFRIGERATED CHICKEN BATTER STATION	110-120V/1/60HZ	3	18	MAX RATING OF BRANCH CIRCUIT FUSE. 15A
55.03	2	VERTICAL CONTACT TOASTER	208V/3/60HZ	10	-	CONNECT TO PRE-WIRED TO RECEPTACLE IN PREP TABLE (#21)

BURGER KING 20/20 GARDEN GRILL INTERIOR INTERIOR LIGHT FIXTURE SCHEDULE								
TYPE	VENDOR	CATALOG No.	WATTAGE	COLOR TEMP	REMARKS			
A	NAUTICAL	BK304 & SP305-18-60D-927-03	10	2700	SHAKER PENDANT LAMP			
		LED EDISON STYLE 10 WATT						
B	NAUTICAL	BK305 & LED 8W EDISON INCANDESCENT	6	2700K	BRONZE CAGE PENDANT LIGHT			
		LED CLEAR ANTIQUE STYLE 6 WATT						
C4w	JUNO	SP36671-WHTRM	15	3000	1. 4" DIAMETER, WHITE, RECESSED DOWN LIGHT			
		CREE	CR4-575L-27K-12-E26	9.5	2700	2. TO BE USED WITH GWB CEILING		
		ENERGYWISE	EWMLDD4IN	11	2700			
C4b	SECURITY	LB4A6L 30K 9 WH / IBOXL	9	3000	1. 4" DIAMETER, BLACK, RECESSED DOWN LIGHT			
		JUNO	SP36671-8LTRM	9.5	2700	2. TO BE USED WITH ACOUSTICAL CEILING TILES		
		CREE	CR4-575L-27K-12-E26-MODBLK	9.5	2700			
D4w	SECURITY	JUNO	SP36671G2 / 39 WWH	12.5	3000	1. 4" DIAMETER, WHITE, RECESSED DOWN LIGHT		
		SECURITY	LB4A6L 30K 9 WH / IBOXL	9	3000	2. TO BE USED WITH GWB CEILING		
F	LEKTRON	LED BK RED EXTERIOR BAND LIGHT-1016	1.5 / FT		LOAD FOOTAGE 32 LINEAL FT. LIGHT BAND DIMENSIONS TO BE VERIFIED IN FIELD BY SIGN MANUFACTURER.			
I	SECURITY	CL-E-TFA04A-24R-40N	42	4000	1. TO BE USED IN KITCHEN			
		LIT24-40-MLG-FA32-EU-C38B	45	4000	2. 2x4 RECESSED			
		LSI	SF24 LED 50 UE DIN40	50	4000			
		VAOPTO	VO-FL-2NH4-60	60	4000			
		ENERGYWISE	EWMLF24EP4841	48	4100			
L	SECURITY	RS-42WLED-UD-SH-120-5300K	30	5300	1. EXTERIOR WALL FIXTURE			
		RW5C30LED-UD-PS-MIT	30	5000	2. OPEN CANOPY FIXTURE			
		LSI	WP36LF13X9U57KMSV	12 UP/ 12 DOWN	5700	3. PROVIDED BY SIGN SUPPLIER WITH CANOPY		
		KONTECH	KON-60-WS-DU	60	5000			
		VAOPTO	VO-WS-DW60UD	60	5000			
M	ENERGYWISE	EWKON-60-WS-DU	60	5000				
		KONTECH	KON-DVP-182-14-4Y	40	5000	1. TO BE USED AT AWNINGS		
		VAOPTO	VO-RP-40DW277-4	40	5000	2. OPTIONAL CLOSED CANOPY FIXTURE		
						3. PROVIDED BY SIGN SUPPLIER WITH		
N	SECURITY	EWMP1X03127	27	4000	1. WALL MOUNTED SECURITY LIGHT			
		WGH-1LU-M	41	5000	2. BRONZE FINISH			
		LSI	SFCMWBLEDPL150UEBRZ	33	5000			
		VAOPTO	VO-WP-DW-N50	50	5000			
		ENERGYWISE	EWALD-WPDS240	40	5000			
WIB	SECURITY	WS4-50L-57K-10V-FD	55	5300	TO BE USED IN WALK IN BOX ONLY			
		LXEM4-50ML-RFA-EU	53	5000				
		LSI	EG345LEDHOCWUE	52	5300			
		VAOPTO	VO-TF-14W	32	5000			
		ENERGYWISE	EWMLD-LSV2XTRUSE4806	36				
EM	SECURITY	EM22RWH	11		EMERGENCY LIGHT			
		CU2	1	3000				
		LSI	LTEMWH	(2) 1 LED	2	5000		
		VAOPTO	VO-EM	2	3000			
		ENERGYWISE	EWCU2	1	3000			
EMX	SECURITY	C-EE-A-EX-2LDF-RED-BB-REM-HL-ST	11		EXIT / EMERGENCY LIGHT. PROVIDE WITH REMOTE HEADS WHERE INDICATED ON PLANS.			
		CCRR	4					
		LSI	LPRXRUBWHLD11R	(2) 1 LED				
		VAOPTO	VO-EMX-R1	2	5000			
		ENERGYWISE	EWCCR	4	3000			

CONTACT INFORMATION

CREE ELVIR SULJIC 262-884-3332 esuljic@creelighting.com	HERMITAGE "MASTER CONSOLIDATOR" WYATT CULVER 615-843-3379 wyatt@hlg.co	ENERGYWISE JENNIFER WADDICK 877-225-1336 jennifer@energywisemail.com	JUNO / ACUITY BRANDS BRETT D KINZLER 847-813-8350 m 847-312-1578 brett.kinzler@acuitybrands.com
SECURITY LIGHTING WHITNEY WATSON 630-550-9320 quotations@securitylighting.com	NAUTICAL FURNISHINGS MICHAEL HOGGLUND 954-771-1100 mhogglund@nauticalfurnishings.com	VaOpto LINDA XU 702-517-5789 linda@vaopto.com	ZANIBONI LIGHTING JENNIFER MORRIS 727-213-0410 southeastusa@zanibonilighting.com
LSI BOB LUCAS 800-436-7800 Ext 4052 bob.lucas@lsi-industries.com			

NOTES

- NOT ALL LIGHT FIXTURES TYPES SHOWN ON SCHEDULE MAY BE USED ON THIS PROJECT. REFER TO LIGHTING PLAN FOR PROJECT SPECIFIC TYPES AND QUANTITIES.
- PENDANT FIXTURES "A" MUST BE CENTERED OVER TABLE TOPS. COORDINATE WITH DECOR DRAWINGS.
- EXCEPT FOR DROPPED CEILING OPTION, ALL LIGHT FIXTURES IN DINING ROOM AREA & RESTROOM CORRIDOR ARE TO BE SUPPORTED FROM EXPOSED ROOF TRUSSES.
- CONTRACTOR TO NOTIFY LIGHTING SUPPLIER OF THE FOLLOWING: FIXTURE TYPES "C" AND "D" WILL BE REQUIRED TO BE LENS AT THE LOCATIONS OVER THE SERVICE AREA AND OVER THE SELF-SERVE DRINK AREA. FIXTURE TYPE "I" WILL REQUIRE A LENS OR TUBE GUARD AT THOSE LOCATIONS.

Issued:	Date:
A BKC Approval	10/29/2021
B Permit Set	1/21/2022
C Bid Set	1/24/2022
D Construction Set	3/14/2022
E	
Revisions:	Date:
1 Addendum #1	02/08/22
2 Addendum #2	02/21/22
3	
4	
5	
6	
7	
8	
9	

Seal	Seal
PROJECT ARCHITECT/ENGINEER	DATE
PROJECT LEAD	DATE
PROJECT DESIGNER	DATE

Copyright © 2022
 APD Engineering & Architecture, LLC
 Drawing Alteration
 It is a violation of law for any person, unless acting under the direction of licensed Architect, Professional Engineer, Landscape Architect, or Land Surveyor to alter any item on this document in any way. Any licensee who alters this document is required by law to affix his or her seal and to add the notation "Altered By" followed by his or her signature and the specific description of the alteration or revision.
 [DO NOT SCALE PLANS]
 Copying, Printing, Software and other processes required to produce these prints can stretch or shrink the actual paper or layout. Therefore, scaling of this drawing may be inaccurate. Contact APD E&A with any need for additional dimensions or clarifications.

APD ENGINEERING ARCHITECTURE
 615 Fishers Run Victor, NY 14564
 585.742.2222 - www.apd.com

Ampler Development LLC
 4700 Falls of Neuse Rd
 Suite 400
 Raleigh, NC 27609
 phone: (513) 484-0945

Burger King Inc.
 Store #
 322 Pottstown Ave
 Pennsburg, PA 18073
 Montgomery County
 Project Name & Location:

Lighting Schedule	
Drawing Name:	Project No.
Date: 11/8/2021	21-0327
Type: ROC-2502T	
Drawn By: MK	E-1.1
Scale: As Noted	Drawing No.