

REVIEWED

For Code Compliance
City of Ocala Growth Management

BLD22-1101 09/07/22

EQUIPMENT CONNECTION SCHEDULE								
ITEM TAG	QTY	MTG HEIGHT	VOLTAGE/ PHASE	DESCRIPTION	CIRCUIT	BRANCH CIRCUIT WIRING	DEVICE	REMARKS
B-215	1	+8"	120/1	WATER HEATER IGNITION	A-71	2#12,1#12G; 3/4"C	MOTOR RATED SWITCH	
C-018	1	+48"	120/1	DUAL OPEN FRYER w/CONTROLLER	B-43	2#12,1#12G; 3/4"C	NEMA 5-20R	
C-025	1	+48"	208/3	8 HEAD FRYER	B-77/79/81	3#4,1#10G; 1-1/4"C		
C-130	1	+18"	208/3	CONVECTION OVEN w/CONTROLLER	B-53/55/57	3#10,1#10G; 1"C		COORDINATE RECEPTACLE REQUIREMENTS WITH EQUIPMENT PROVIDED.
C-182	1	+18"	208/3	CONVECTION OVEN	B-59/61/63	3#6,1#10G; 1"C		COORDINATE RECEPTACLE REQUIREMENTS WITH EQUIPMENT PROVIDED.
C-184	2	+48"	208/3	PRESSURE FRYER	B-65/67/69 B-71/73/75	3#4,1#10G; 1-1/4"C EA		COORDINATE RECEPTACLE REQUIREMENTS WITH EQUIPMENT PROVIDED.
C-183	2	+42"	208/1	MICROWAVE OVEN	B-68/68 B-70/72	2#12,1#12G; 3/4"C EA	NEMA 5-20R	
C-212	1	PACK LINE	120/1	BUN TOASTER	A-13 A-25	2#12,1#12G; 3/4"C	NEMA L5-20R	
E-241	1	+108"	120/1	HOOD FIRE SUPPRESSION SYSTEM	B-44	2#12,1#12G; 3/4"C	JUNCTION BOX	
F-040	1	+42"	120/1	OFFICE COMPUTER	A-15	2#12,1#12G; 3/4"C	NEMA 5-20R-IG	
F-050	2	+24"	120/1	CREDIT CARD ROUTER	A-80	2#12,1#12G; 3/4"C	NEMA 5-20R-IG	
F-060	2	+24"	120/1	COMPUTER MONITOR	A-15	2#12,1#12G; 1#12IG; 3/4"C	NEMA 5-20R-IG	
F-080	1	+24"	120/1	OFFICE PRINTER/COPIER/ FAX/SCANNER	A-80	2#12,1#12G; 1#12IG; 3/4"C	NEMA 5-20R-IG	
F-090	1	+24"	120/1	UPS	A-15	2#12,1#12G; 1#12IG; 3/4"C	NEMA 5-20R-IG	
F-131	1	+80"	120/1	MUSIC SYSTEM (MUZAK)	A-50	2#12,1#12G; 1#12IG; 3/4"C	NEMA 5-20R-IG	
F-170	1	+24"	120/1	SAFEW/TOUCH SCREEN CNTRL	A-6	2#12,1#12G; 1#12IG; 3/4"C	NEMA 5-20R-IG	
N-014	1	+18"	208/3	POWER SOAK	A-79/81/83	3#10,1#10G; 1"C	JUNCTION BOX	COORDINATE RECEPTACLE REQUIREMENTS WITH EQUIPMENT PROVIDED.
P-083	1	PACK LINE	208/1	WARMER/FRY CRISP N HOLD	A-39/41	2#10,1#10G; 3/4"C	JUNCTION BOX	COORDINATE RECEPTACLE REQUIREMENTS WITH EQUIPMENT PROVIDED.
P-078	1	PACK LINE	120/1	COLD WELL TABLE	A-44	2#12,1#12G; 3/4"C	NEMA 5-20R	
P-463	2	+80"	208/1	HOT WATER DISPENSER	A-9/11 B-20/22	2#8,1#10G; 1"C EA	JUNCTION BOX	COORDINATE RECEPTACLE REQUIREMENTS WITH EQUIPMENT PROVIDED.

GENERAL NOTE:
COORDINATE ALL RECEPTACLE AND DEVICE TYPES WITH MANUFACTURER RECOMMENDATIONS.

P-601	2	+18"	120/1	BREADER	A-12 A-18	2#12,1#12G; 3/4"C EA	NEMA 5-20R	
R-002	1			FREEZER				
R-030	1	+18"	120/1	1/2 HEIGHT FREEZER	B-56 B-58	2#12,1#12G; 3/4"C EA	NEMA 5-20R	
S-015	2	PACK LINE	120/1	1/2 HEIGHT HEATED CABINET	A-28 A-28	2#12,1#12G; 3/4"C EA	NEMA 5-20R	
S-017	1	+18"	120/1	FULL HEIGHT HEATED CABINET	A-35		NEMA 5-20R	
S-044	1	PACK LINE	208/1	BUNN HOLDING CABINET	A-34/36	2#12,1#12G; 3/4"C	NEMA L6-15R	
S-053	1	PACK LINE	208/1	HOLDING CABINET	A-40/42	2#12,1#12G; 3/4"C	NEMA L6-15R	
S-087	1	PACK LINE		INFRARED HOLDING BIN				
S-251	1	+84"	120/1	D/T TIMING SYSTEM	A-10	2#12,1#12G; 1#12IG; 3/4"C	NEMA 5-20R-IG	
S-404	1	+24"	120/1	TEA BREWER D/T	A-32	2#12,1#12G; 3/4"C	NEMA 5-20R	
S-514	2	+84"	120/1	ICE MAKERS S/S & D/T (2)	A-48 A-52	2#12,1#12G; 3/4"C	NEMA 5-20R	
S-514	2	ROOF TOP	208/1	REMOTE CONDENSER S/S REMOTE CONDENSER D/T	A-54/56 A-58/60	2#12,1#12G; 3/4"C EA	NEMA L6-30R	
S-532	2	+48"	120/1	FROZEN BEV. DISPENSER	A-1 A-3	2#10,1#10G; 3/4"C EA	NEMA L6-30R	
S-570	2	+18"	120/1	CARBONATOR	A-8 A-20	2#12,1#12G; 3/4"C EA	NEMA 5-20R	
U-008	1	+90"	120/1	BASE STATION-DT COMM SYSTEM	A-16	2#12,1#12G; 1#12IG; 3/4"C	NEMA 5-20R-IG	
U-050	1		120/1	SECURITY SYSTEM	A-17	2#12,1#12G; 3/4"C	NEMA 5-20R	
U-031	1	+24"	120/1	CCTV & MONITOR	A-14	2#12,1#12G; 1#12IG; 3/4"C EA	NEMA 5-20R-IG	
U-070	3	+24"	120/1	RECEIPT PRINTER	A-4 A-22	2#12,1#12G; 1#12IG; 3/4"C EA	NEMA 5-20R-IG	
U-100	4	+18"	120/1	POS ORDER ENTRY	A-4 A-22	2#12,1#12G; 1#12IG; 3/4"C EA	NEMA 5-20R-IG	
U-198	6	+90"	120/1	ORDER MONITOR	A-38	2#12,1#12G; 1#12IG; 3/4"C	NEMA 5-20R-IG	
W-212	1	ROOF TOP	208/3	WALK-IN CHICKEN COOLER	A-43/45/47	3#12,1#12G; 3/4"C	JUNCTION BOX	REFER TO ROOF PLAN. PROVIDE ALL INTERCONNECTIVE WIRING BETWEEN INDOOR AND OUTDOOR UNIT PER MANUFACTURER'S RECOMMENDATIONS.
W-212	1	ROOF TOP	208/3	WALK-IN PRODUCE COOLER	A-49/51/53	3#12,1#12G; 3/4"C	JUNCTION BOX	REFER TO ROOF PLAN. PROVIDE ALL INTERCONNECTIVE WIRING BETWEEN INDOOR AND OUTDOOR UNIT PER MANUFACTURER'S RECOMMENDATIONS.
W-212	1	ROOF TOP	208/3	WALK-IN FREEZER	A-55/57/59	3#12,1#12G; 3/4"C	JUNCTION BOX	REFER TO ROOF PLAN. PROVIDE ALL INTERCONNECTIVE WIRING BETWEEN INDOOR AND OUTDOOR UNIT PER MANUFACTURER'S RECOMMENDATIONS.

ARCHITECTURE
ENGINEERING

LIS

LAND INVESTMENT SERVICES, LLC
AA 26002040 CA NO: 6853 LB1057

ARCHITECTURE / ENGINEERING OFFICE
11000 W. U.S. 90, Suite 2064, Ocala, FL 32765
Phone: (321) 244-0402
Facsimile: (321) 244-9419

Digitally signed by
ROBERT W CASE
Date:
2022.03.31
10:23:02
-04'00'

ROBERT WAYNE CASE
FLORIDA PE #44643

- PLAN SET REVISIONS:
- △
 - △
 - △
 - △
 - △
 - △
 - △
 - △
 - △
 - △

CONTRACT DATE: ...-2019
BUILDING TYPE: Kb 30-19
PLAN VERSION: 2018.A
SITE NUMBER:
ENTITY NUMBER:
STORE NUMBER:
LIS PROJECT: 2019-304

KFC
3615 W SILVER SPRINGS BLVD.
OCALA, FL



EQUIPMENT SCHEDULES

E2.2